



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (2) in WSD 3321/2025 T/J(279/2025)

9 January 2026

**Approval of “WARCO” Check Valves  
(General Acceptance No. C20260024)**

Your E-Application [file-id: ET J-GA-20250328-81] dated 28 March 2025 and subsequent submissions received by this department up to 30 December 2025 refer.

Having considered the test report ref. RNJE005r5 issued on 29 December 2025 by Ideal Test Consultants Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Whcon (Beijing) Fluid Systems Co Ltd

**Country of Origin:** Chinese Mainland

**Brand:** Warco

**Details of Fitting:** Ductile iron silent check valve with epoxy powder coating under WRAS approval no. 2202530

**Model:** 6320

**Size:** 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm

**Body Markings:** **WARCO**

**Expiry Date:** 31 December 2026

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
         ME/MC            ] - with soft copy only



6320