



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(5/2026)

13 March 2026

**Approval of "KEMBLA" Copper Fittings
(General Acceptance No. C20260171)**

Your letters dated 7 January 2026 and 11 February 2026 refer.

Having considered the test report ref. BC-SUMMARY-2026-001 issued on 2 January 2026 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: TM Autocast Co Ltd

Country of Origin: Thailand

Brand: Kembla

Details of Fittings: Copper alloy fittings with solder ring connection ends

Description	Model	Size
Female 90° Elbow	SFEN	15x½", 22x½", 22x¾", 28x1" (mm x inch)
Male 90° Elbow	SMEN	15x½" (mm x inch)
Female Connector	SFCC	15x½", 22x¾", 28x1", 35x1¼" (mm x inch)
Male Connector	SMCC	15x½", 22x¾", 28x1", 35x1¼", 42x1½", 54x2" (mm x inch)

Description	Model	Size
Female Connector (Reducer)	SFCC	22x½" (mm x inch)
Female Tee	SFTE	15x15x½", 22x22x½" (mm x mm x inch)

Body Markings: KEMBLA  (Size) x (Inch)

Expiry Date: 31 December 2027


This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,


(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Female 90° Elbow



Male 90° Elbow



Female Connector



Male Connector



Female Connector
(Reducer)



Female Tee