



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4355

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3611/13/98 Pt.8 T/J(52)

13 April 2017

**Application for Permission for Connection to a Main
“TGC” Instantaneous Gas Water Heater
Model : ST12HD**

Your letters ref. GUD/RP/WSD/17/L85 and GUD/RP/WSD/17/L085-B dated 24 March 2017 and 30 March 2017 respectively refer.

After examining the technical information, it is considered from water supply point of view that the captioned instantaneous gas water heater is suitable for direct connection to waterworks mains subject to the following conditions:-

- (1) Name of Manufacturer: Taiwan Sakura Corporation
- (2) Country of Origin: Taiwan
- (3) Details of water heater.

Model	Max. Working Pressure	Min. Working Pressure	Min. Working Water Flow
ST12HD	10 bar	0.2 bar	3 l/min

- (4) The water heater is not suitable for use in drinking water purpose.

- (5) You are required to ensure that this water heater should also comply with the requirements of Electrical & Mechanical Services Department.
- (6) Installation of the heater must be in full compliance with the conditions stipulated in Part 4 of Schedule 2 of Waterworks Regulations, Chapter 102A. Your particular attention is drawn to that the heater is required to have a guaranteed test pressure of at least 1.5 times the static head available at the heater.
- (7) Expiry Date : 6 December 2021

This letter should not be regarded as a certification/approval on the construction, quality, durability, efficiency etc. of the water heater as these aspects should remain to be the manufacturer's guarantee. The permission given by this letter will be withdrawn if the water heater is found to be unsuitable for use in fresh water plumbing systems.

Proviso: Our permission is based on the condition that the water heater will be installed individually. If such heater is to be installed in series or in parallel with other heater, submission of plumbing proposal for each individual project to the Water Authority for approval is required and off-tank may be needed. Notwithstanding the above, you are required to ensure that the water heater should also comply with the requirements of Electrical & Mechanical Services Department.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,


(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



ST12HD