



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件  
e-mail wsdinfo@wsd.gov.hk

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3611/13/98 Pt.8 T/J(65)

3 May 2018

**Application for Permission for Connection to a Main  
“RINNAI” Instantaneous Gas Water Heater  
Model : RS11TML**

Your letters ref. RPQD/RP/WSD/18/L96 and RPQD/RP/WSD/18/L96-B dated 3 April 2018 and 20 April 2018 respectively refer.

After examining the technical information, it is considered from water supply point of view that the captioned instantaneous gas water heater is suitable for direct connection to waterworks mains subject to the following conditions:-

- (1) Name of Manufacturer: Rinnai Corporation
- (2) Country of Origin: China
- (3) Details of water heater.

| Model   | Max. Working Pressure | Min. Working Pressure | Min. Working Water Flow |
|---------|-----------------------|-----------------------|-------------------------|
| RS11TML | 10 bar                | 0.1 bar               | 2.4 l/min               |

- (4) The water heater is not suitable for use in drinking water purpose.
- (5) You are required to ensure that this water heater should also comply with the requirements of Electrical & Mechanical Services Department.

- (6) Installation of the heater must be in full compliance with the conditions stipulated in Part 4 of Schedule 2 of Waterworks Regulations, Chapter 102A. Your particular attention is drawn to that the heater is required to have a guaranteed test pressure of at least 1.5 times the static head available at the heater.

(7) Expiry Date : 9 August 2022

This letter should not be regarded as a certification/approval on the construction, quality, durability, efficiency etc. of the water heater as these aspects should remain to be the manufacturer's guarantee. The permission given by this letter will be withdrawn if the water heater is found to be unsuitable for use in fresh water plumbing systems.

Proviso: Our permission is based on the condition that the water heater will be installed individually. If such heater is to be installed in series or in parallel with other heater, submission of plumbing proposal for each individual project to the Water Authority for approval is required and off-tank may be needed. Notwithstanding the above, you are required to ensure that the water heater should also comply with the requirements of Electrical & Mechanical Services Department.


Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)  
for Water Authority

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



**RS11TML**