



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3611/11/96 Pt.36 T/J(18)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 February 2024

**Application for Permission for Connection to a Main
“VIESSMANN” Instantaneous Electric Water Heaters
(General Acceptance No. H20240001)**

Your letters dated 22 September 2023, 11 November 2023 and 18 January 2024 refer.

After examining the technical information, it is considered from water supply point of view that the captioned instantaneous electric water heaters are suitable for direct connection to waterworks mains subject to the following conditions:-

- (1) Name of Manufacturer: Kospel Sp zoo
- (2) Country of Origin: Poland
- (3) Details of water heaters.

Brand	Model	Max. Working Pressure	Min. Working Pressure	Min. Working Water Flow
Viessmann	Vitotherm EI Premium 18/21/24	10 bar	1 bar	2.5 l/min
Viessmann	Vitotherm EI Premium 27	10 bar	1 bar	2.5 l/min

Brand	Model	Max. Working Pressure	Min. Working Pressure	Min. Working Water Flow
Viessmann	Vitotherm EI Classic 18/21/24	10 bar	1 bar	2.5 l/min
Viessmann	Vitotherm EI Classic 27	10 bar	1 bar	2.5 l/min

- (4) The water heaters are not suitable for use in drinking water purpose.
- (5) You are required to ensure that these water heaters should also comply with the requirements of Electrical & Mechanical Services Department.
- (6) Installation of the heaters must be in full compliance with the conditions stipulated in Part 4 of Schedule 2 of Waterworks Regulations, Chapter 102A. Your particular attention is drawn to that the heaters are required to have a guaranteed test pressure of at least 1.5 times the static head available at the heaters.
- (7) Expiry Date : 22 October 2028

This letter should not be regarded as a certification/approval on the construction, quality, durability, efficiency etc. of the water heaters as these aspects should remain to be the manufacturer's guarantee. The permission given by this letter will be withdrawn if the water heaters are found to be unsuitable for use in fresh water plumbing systems.

Proviso: Our permission is based on the condition that the water heaters will be installed individually. If such heaters are to be installed in series or in parallel with other heaters, submission of plumbing proposal for each individual project to the Water Authority for approval is required and off-tank may be needed. Notwithstanding the above, you are required to ensure that the water heaters should also comply with the requirements of Electrical & Mechanical Services Department.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)


for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only




Vitotherm El Premium 18/21/24



Vitotherm El Premium 27



Vitotherm El Classic 18/21/24



Vitotherm El Classic 27