



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4355

圖文傳真
Facsimile

2824 0578

檔號
Reference

(3) in WSD 3321/16 Pt.1 T/J(1515)

14 November 2016

Approval of "IPLEX" uPVC Pipes

Your letter ref. IPLEXPRESSUREPIPES20161104/01 dated 4 November 2016 refers.

Having considered the test report ref. BC0160908-033-MISL issued on 6 October 2016 by Castco Testing Centre Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guanzhou ANMEI Shiye Co Ltd

Country of Origin: China

Brand: Iplex

Details of Pipes: uPVC pressure pipes in white colour (Class E)

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings:

For 65mm:

iPLex HIGH PRESSURE U-PVC 65mm
AS/NZS 1477 PN15 GS

For others:

iPLex HIGH PRESSURE U-PVC size in mm
BS3505 CLASS E GS

Expiry Date:

20 September 2021

Proviso: As the pipes have not been tested for use in contact with water intended for human consumption, the pipes can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipes in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipes in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only