



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2024 T/J(1319/2024)

24 January 2025

**Approval of "PEGLER" Gate Valves
(General Acceptance No. ZA20250003)**

Your letters ref. Q-1439/24, Q-1470/24 and Q-1484/25 dated 8 November 2024, 10 December 2024 and 2 January 2025 respectively refer.

The licence no. KM 628350 has been examined. It is noted that the British Standards Institution (BSI) has granted Aalberts Integrated Piping Systems Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the fittings described below based on Kitemark certificate and test report ref. BC-SUMMARY-2024-168 issued on 2 December 2024 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aalberts Integrated Piping Systems Ltd

Country of Origin: UK

Brand: Pegler

Details of Fittings: Copper alloy gate valve

Model: Fig.1068

Size: ½", ¾", 1", 1¼"



Body Markings: PEGLER ENGLAND Size PN

Expiry Date: 28 September 2029

In view of BSI granting licence to Aalberts Integrated Piping Systems Ltd on BS EN 12288 "Copper alloy gate valves" as mentioned above, approval is hereby given to the said water supply fittings to be used in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fittings if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Fig.1068