



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2025 T/J(173/2025)

9 June 2025

**Approval of “KEY” Ductile Iron Pipes
(General Acceptance No. ZA20250019)**

Your letter ref. BK2025-AC-KEY-006 dated 3 March 2025 and subsequent submissions received by this department up to 14 May 2025 refer.

The licence no. KM 645979 has been examined. It is noted that the British Standards Institution (BSI) has granted Suns Pipelines Company Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate, WRAS certificates and test reports ref. 250103-2190 and 250103-2191 issued on 6 May 2025 and 8 May 2025 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Suns Pipelines Company Limited

Country of Origin: the Mainland of China

Brand: Key



Details of Pipes:	Ductile iron pipes with push in flexible joints (Class C and K) and Ductile iron pipes with welded-on / cast-on flanges both with internal epoxy seal coat (under WRAS approval no. 2212528) for cement mortar lining (under WRAS approval no. 2105500)
Size:	80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm
Body Markings:	KEY
Expiry Date:	8 June 2030

In view of BSI granting licence to Suns Pipelines Company Limited on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Ductile iron pipes with push in flexible joints (Class C and K)



Ductile iron pipes with welded-on / cast-on flanges