



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 6 ) in WSD 3321/2025 T/J(502/2025)

25 September 2025

**Approval of “WINSTON” Copper Pipes  
(General Acceptance No. ZA20250026)**

Your letter ref. CYH-WSD-0046 dated 30 May 2025 and subsequent submissions received by this department up to 29 August 2025 refer.

The licence no. KM 706271 has been examined. It is noted that the British Standards Institution (BSI) has granted Ningbo Jintian Copper Tube Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate and test report ref. BC-SUMMARY-2025-299 issued on 23 July 2025 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Ningbo Jintian Copper Tube Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** Winston

**Details of Pipes:** Copper pipes (Table X)

| Temper | Size (mm)              |
|--------|------------------------|
| R250   | 15x0.7, 22x0.9, 28x0.9 |



| Temper | Size (mm)                                                       |
|--------|-----------------------------------------------------------------|
| R290   | 35x1.2, 42x1.2, 54x1.2, 66.7x1.2,<br>76.1x1.5, 108x1.5, 159x2.0 |

**Body Markings:**

For R250:

WINSTON  BS EN1057 (Size) x (Thickness)-X  
I-I-I  Production Month/Year

For R290:

WINSTON  BS EN1057 (Size) x (Thickness)-X  
R290  Production Month/Year

**Expiry Date:**

24 September 2030

In view of BSI granting licence to Ningbo Jintian Copper Tube Co Ltd on BS EN 1057 "Copper and copper alloy. Seamless, round copper tubes for water and gas in sanitary and heating applications" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only