



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(1095/2025)

18 November 2025

**Approval of “TATA DUCTURA” Ductile Iron Pipes
(General Acceptance No. ZA20250031)**

Your letter ref. CYH-WSD-0049 dated 20 October 2025 refers.

The licence no. KM 639475 has been examined. It is noted that the British Standards Institution (BSI) has granted Tata Steel Limited Metaliks Division the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate, WRAS certificates and test reports ref. 241204-2118 and 250821-2088 issued on 10 April 2025 and 1 September 2025 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tata Steel Limited – Metaliks Division

Country of Origin: India

Brand: Tata Ductura

Details of Pipes: Ductile iron pipes with push in flexible joints (Class C, K9 and K12) with internal epoxy seal coat (under WRAS approval no. 2201527) for cement mortar lining (under WRAS approval no. 251055002)



Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm

Body Markings: TATA DUCTURA  BSEN 545 (Size) (Length)
(Class C) (Class K)

Expiry Date: 17 November 2030

In view of BSI granting licence to Tata Steel Limited Metaliks Division on BS EN 545 "Ductile iron pipes, fittings, accessories and their joints for water pipelines" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)


for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Ductile iron pipes with push in flexible joints (Class C)



Ductile iron pipes with push in flexible joints (K9)



Ductile iron pipes with push in flexible joints (K12)