



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail
wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile
2824 0578

檔號
Reference
(4) in WSD 3321/2025 T/J(1020/2025)

29 December 2025

**Approval of “CONEX DELCOP” Copper Fittings
(General Acceptance No. ZA20250036)**

Your letters dated 8 October 2025 and 26 November 2025 refer.

The licence no. KM 07283 has been examined. It is noted that the British Standards Institution (BSI) has granted Conex Universal Limited the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the fittings described below based on Kitemark certificate and test report ref. BC-SUMMARY-2025-386 issued on 21 November 2025 by Castco Testing Centre Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Conex Universal Limited

Country of Origin: Spain

Brand: Conex Delcop


Details of Fittings: Copper fittings with end feed connection ends

Description	Model	Size (mm)
Coupling (c x c)	DC601/5270	15, 22, 28, 35, 42, 54
Reduced Coupling (c x c)	DC601R/5240	22x15, 28x15, 28x22, 35x28, 42x35
Fitting Reducer (fitting x c)	DC6012/5243	22x15, 28x15, 28x22, 35x22, 35x28, 42x28, 42x35



Description	Model	Size (mm)
45° Elbow	DC606/5041	22, 28
Elbow 90° (c x c)	DC607/5090	15, 22, 28, 35, 42, 54
Tee Equal (c x c x c)	DC611/5130	15, 22, 28
Reducing Tee (c x c x c)	DC611R/5130	22x15x15, 22x15x22, 22x22x15, 28x22x22, 28x28x15, 28x28x22
Cap (c)	DC617/5301	15, 22, 28

Body Markings:



Expiry Date:

28 December 2030

In view of BSI granting licence to Conex Universal Limited on BS EN 1254 / BS 864 Part 2 "Copper and copper alloy – Plumbing fittings" as mentioned above, approval is hereby given to the said water supply fittings to be used on fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply fittings if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,

(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Coupling (c x c)



Reduced Coupling (c x c)




Fitting Reducer (fitting x c)



45° Elbow



Elbow 90° (c x c)



Tee Equal (c x c x c)



Reducing Tee (c x c x c)



Cap (c)