



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (14) in WSD 3321/2025 T/J(1087/2025)

28 May 2026

**Approval of “ERA” PE Pipes
(General Acceptance No. ZA20260012)**

Your letter dated 3 October 2025 and subsequent submissions received by this department up to 4 May 2026 refer.

The licence no. KM 654656 has been examined. It is noted that the British Standards Institution (BSI) has granted ERA Co Ltd the right and licence to use the Kitemark for goods as set out below. This Authority accepts that the pipes described below based on Kitemark certificate, WRAS approval no. 2207543 and test report ref. 252724EN253283D issued on 9 March 2026 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: ERA Co Ltd

Country of Origin: Chinese Mainland

Brand: ERA

Details of Pipes: PE pipes in black colour

Description	Size (mm)
PE100, SDR11	20, 25, 32, 40, 50, 63, 75, 90, 110, 125, 160, 200, 225, 315, 355, 400, 450, 500, 560, 630
PE100, SDR17	75, 90, 110, 125, 160, 200, 225, 315, 355, 400, 450, 500, 560, 630



Body Markings:

ERA EN 12001-2 / ISO 4427-2 $d_n \times e_n$ 
 SDR W/P PE100 PN16 YYMMDD

Expiry Date:

27 May 2031

In view of BSI granting licence to ERA Co Ltd on BS EN 12201-2 "Plastic piping systems for water supply, and for drainage and sewerage under pressure – Polyethylene (PE) Part 2: Pipes" as mentioned above, approval is hereby given to the said water supply pipes to be used on fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

This Authority reserves the right to withdraw the approval given to the use of the water supply pipes if they are found afterwards not suitable for use in the water supply systems mentioned above in terms of quality or unacceptability of material.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only