



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞  
e-mail

wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

( 8 ) in WSD 3321/2025 T/J(957/2025)

12 February 2026

**Approval of "TCK" Sensor Tap  
(General Acceptance No. ZB20260006)**

Your letter ref. HX/W/1896/25 dated 12 September 2025 and subsequent submissions received by this department up to 19 January 2025 refer.

It is noted that the fitting described below has been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the Water Supply (Water Fittings) Regulations (England & Wales), the Water Supply (Water Fittings) (Scotland) Byelaws and the Water Supply (Water Fittings) Regulations (Northern Ireland) when correctly installed. This Authority accepts that the fitting described below based on the WRAS certificate and test report ref. 243753PC250594B issued on 9 December 2025 by Fugro Technical Services Limited complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Xiamen OLT Co Ltd

**Country of Origin:** Chinese Mainland

**Brand:** TCK

**Details of Fitting:** 1/2" Deck mounted sensor tap with 1 no. of flexible hose approved by UK's WRAS under ref. 250102002

**Model:** LT0042



**Body Markings:** TCK on body

**WRAS Approval Number:** 2312310

**Installation Requirements:** R001, R006  
(Appendix A of WRAS approval letter refers)

**Expiry Date:** 11 February 2031

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

“A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply.” AND

“The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc.”


A condition of this acceptance is that the fitting to be installed should be replicas of the sample certified by WRAS and no modification should be made to the fitting. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

A handwritten signature in blue ink, appearing to be 'Chan Kwok Leung', written over a blue line that extends from the signature down towards the name below.

(CHAN Kwok Leung, Douglas)  
for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



LT0042