



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2026 T/J(575/2026)

6 August 2026

**Approval of “MALGORANI” Pressure Reducing Valves
(General Acceptance No. ZB20260018)**

Your letters ref. WSD-143-26-L002-1 and WSD-143-26-L003-1 dated 10 June 2026 and 9 July 2026 respectively refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the Water Supply (Water Fittings) Regulations (England & Wales), the Water Supply (Water Fittings) (Scotland) Byelaws and the Water Supply (Water Fittings) Regulations (Northern Ireland) when correctly installed. This Authority accepts that the fittings described below based on the WRAS certificate and test report ref. 253209PC250979C issued on 2 July 2026 by Fugro Technical Services Limited comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rubinetteria Malgorani Pietro Srl

Country of Origin: Italy

Brand: Malgorani

Details of Fitting: Copper alloy pressure reducing valve

Model: Eurobrass 143 FF



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



Accredited by The Hong Kong Council of Social Service
香港社會服務會

Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm

Body Markings: PN, made in Italy, , size &  on body.
CR on DZR brass valves.

WRAS Approval Number: 241204713

Installation Requirements: R001, R120
(Appendix A of WRAS approval letter refers)

Expiry Date: 5 August 2031

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –


“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. ZB20260018



Eurobrass 143 FF