



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2024 T/J(1013/2024)

12 February 2025

**Approval of "GIACOMINI" Ball Valves
(General Acceptance No. ZC20250097FS)**

Your E-Application [file-id: ETJ-GA-20240924-326] dated 24 September 2024 and subsequent submissions received by this department up to 16 January 2025 refer.

Having considered the test report ref. J29917A-Fr4 issued on 15 January 2025 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below complies with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Giacomini SpA

Country of Origin: Italy

Brand: Giacomini

Details of Fittings: Copper alloy ball valve

Model and Size: R250ZX003 - ½"
R250ZX004 - ¾"
R250ZX005 - 1"
R250ZX006 - 1¼"
R250ZX007 - 1½"
R250ZX008 - 2"



Body Markings:

For size ½" and 1":



size in DN ITALY Production date size in inch

For size ¾":

size in DN MADE IN ITALY Production date
size in inch

For size 1¼":

size in DN CE ITALY Production date
size in inch

For size 1½" and 2":

size in DN CE MADE IN ITALY
Production date size in inch**Expiry Date:**

11 February 2030

Proviso:

The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only

General Acceptance No. ZC20250097FS



R250ZX003 / R250ZX004 / R250ZX005 / R250ZX006 / R250ZX007 / R250ZX008