



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(8) in WSD 3321/2024 T/J(1380/2024)

27 March 2025

**Approval of “RELIABLE” Butterfly Valves
(General Acceptance No. ZC20250206FS)**

Your letter ref. AWSD0002/24 dated 29 November 2024 and subsequent submissions received by this department up to 5 March 2025 refer.

Having considered the test report ref. J30042A-Gr2 issued on 19 February 2025 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Reliable Automatic Sprinkler Co Inc

Country of Origin: the Mainland of China

Brand: Reliable

Details of Fittings: Ductile iron grooved type butterfly valve

Model: REL363GT

Size: 2", 2½", 3", 4", 6", 8", 10"

Body Markings: **Reliable** size in inch

Expiry Date: 26 March 2030



Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



REL363GT