



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(146/2025)

15 April 2025

Signed: General Manager
For the Director of Water Supply
The Water Supplies Department
Kowloon, Hong Kong

(Name of the Director of Water Supply)

Date: 15/4/25

**Approval of “PSV” Butterfly Valves
(General Acceptance No. ZC20250266FS)**

Your letters ref. WSD-3610G-25-L001 and WSD-3610G-25-L002 dated 26 February 2025 and 21 March 2025 respectively refer.

Having considered the test report ref. 244196PC240577A issued on 14 March 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd UK

Country of Origin: the Mainland of China

Brand: PSV

Details of Fittings: Ductile iron butterfly valve

Model: 3610G

Size: 65mm, 80mm, 100mm, 150mm, 200mm, 250mm

Body Markings: PSV DI size in inch

Expiry Date: 14 April 2030



Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



3610G