



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025T/J(274/2025)

25 April 2025

**Approval of “WATERTEC” Flexible Hose
(General Acceptance No. ZC20250279)**

Your E-Application [file-id: ETJ-GA-20250326-74] dated 28 March 2025 refers.

Having considered the test report ref. 240927-2238 issued on 11 March 2025 by Castco Testing Centre Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Watertec (Malaysia) Sdn Bhd

Country of Origin: Malaysia

Brand: Watertec

Details of Fitting: Plastic inlet flexible hose for tap/mixer

Model: WA-PERTCON-100

Size: Bore diameter: 10mm
End connection: 1/2"

Body Markings: Watertec PERT Class 2/10 bar at Max. Temp 85°C



Expiry Date: 24 April 2030

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



WA-PTCON-100