



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(189/2025)

28 April 2025

**Approval of “SUN” Flexible Joints
(General Acceptance No. ZC20250282FS)**

Your E-Application [file-id: ETJ-GA-20250305-58] dated 6 March 2025 and subsequent submission received by this department on 26 March 2025 refer.

Having considered the test report ref. 244471PC250029(1) issued on 13 February 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wah Nan Fire Fighting Equipment Co Ltd

Country of Origin: the Mainland of China

Brand: SUN

Details of Fitting: Twin sphere rubber flexible joint

Model: WH034A

Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm

Body Markings:  size in DN PN16

Expiry Date: 27 April 2030



東江水供港



香港環境卓越大獎
Hong Kong Award for Environmental Excellence



15+ years caring organisation

Proviso: The fittings can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fittings in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



WH034A