



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(362/2025)

14 May 2025

**Approval of "SRI" Hydrant Valve
(General Acceptance No. ZC20250319FS)**

Your letter ref. AWS0009/24(2) dated 15 April 2025 refers.

Having considered the test report ref. J30226r2 issued on 17 March 2025 by Nutek Systems (HK) Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Steel Recon Industries Sdn Bhd
Country of Origin: Malaysia
Brand: SRI
Details of Fitting: 80mm Copper alloy low pressure hydrant valve
Model: DRS097-GM-80BSP
Body Markings: **SRI** 80
Expiry Date: 24 January 2031



Proviso: The fitting can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fitting in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water fire service systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



DRS097-GM-80BSP