



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(5) in WSD 3321/2025 T/J(120/2025)

23 May 2025

**Approval of “YUNG YU” Flexible Joint
(General Acceptance No. ZC20250346)**

Your letters dated 14 February 2025, 15 April 2025 and 28 April 2025 refer.

Having considered the test reports ref. PMA43954A and AGA50112 issued on 17 March 2025 and 26 March 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yung Yu Special Joint Co Ltd

Country of Origin: Taiwan, China

Brand: Yung Yu

Details of Fitting: Ductile iron flexible joint with epoxy powder coating under WRAS approval no. 2309512

Model: Globe Type

Size: 50mm

Body Markings: DN 50 16 kgf/cm²

Expiry Date: 22 May 2030



This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Globe Type