



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(8) in WSD 3321/2025 T/J(326/2025)

24 June 2025

**Approval of “CROWN” UPVC Fittings
(General Acceptance No. ZC20250426F)**

Your letter ref. uPVC/PF/AL/04025008 dated 1 April 2025 and subsequent submissions received by this department up to 3 June 2025 refer.

Having considered the test report ref. 250493PC250225C issued on 3 June 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangdong Nam Sok Building Material Products Co Ltd

Country of Origin: the Mainland of China

Brand: Crown

Details of Fittings: uPVC fittings in white colour

Description	Size (mm)
45° Elbow	160
90° Elbow	160, 200
Reducing Tee	160x160x110, 200x200x160
Reducer	160x110, 200x160

Body Markings:

For Elbow:

 size x angle PVC-U pressure rating
BS4346 AS1477 code no.

For Tee and Reducer:

 size x size PVC-U pressure rating
BS4346 AS1477 code no.
Expiry Date:

23 June 2030

Proviso:

As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



45° Elbow



90° Elbow



Reducing Tee



Reducer