



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2025 T/J(464/2025)

25 June 2025

**Approval of “TYT” Gate Valves
(General Acceptance No. ZC20250432)**

Your letters ref. WSD-20-05-2025 and WSD-03-06-2025-A dated 20 May 2025 and 3 June 2025 respectively refer.

Having considered the test report ref. 250804PC250255A issued on 30 May 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: M/s Goodyear Valves Works Corp
Country of Origin: Taiwan, China
Brand: TYT
Details of Fittings: Copper alloy gate valve
Model: H3110
Size: 15mm, 20mm, 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm
Body Markings: TYT size in inch 125



東江水供港



香港環境卓越大獎



15+ years caring organisation
Announced by The Hong Kong School of Social Service
香港社會服務發展局

Expiry Date: 6 August 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



H3110