



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(506/2025)

30 June 2025

**Approval of “VALVEMAKER” Stop Valves
(General Acceptance No. ZC20250450)**

Your letter ref. BK2025-AC-VALVEMAKER-022 dated 2 June 2025 refers.

Having considered the test report ref. BC-SUMMARY-2025-183 issued on 14 May 2025 by Castco Testing Centre Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Rian Valve Co Ltd

Country of Origin: the Mainland of China

Brand: Valvemaker

Details of Fittings: Copper alloy loose jumper stop valve

Model: BR303

Size: 20mm, 25mm, 32mm, 40mm

Body Markings: V-MAKER (Size) ← (PN)

Expiry Date: 29 June 2030



東江水供港
Hong Kong's Water Supply 50th Anniversary



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ 同心展關懷
caringorganisation
Awarded by The Hong Kong Council of Social Service
獲香港社會服務處頒發

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



BR303