



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2025 T/J(335/2025)

4 July 2025

**Approval of “TUB-E” Copper Pipes
(General Acceptance No. ZC20250469)**

Your letter ref. BK2025-AC-TUB-E-018 dated 14 April 2025 and subsequent submissions received by this department up to 5 June 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-111 issued on 3 April 2025 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mueller Europe Limited

Country of Origin: UK

Brand: tub-e

Details of Pipes: 1. Copper pipes (Class X)

Model	Temper	Size (mm)
PREMIUM	R250	15x0.7, 22x0.9, 28x0.9
	R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5



2. Copper pipes with polyethylene sheath for cold water applications (Class X)

Model	Temper	Size (mm)
INSO	R250	15x0.7, 22x0.9, 28x0.9
	R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5

3. Copper pipes with profiled polyethylene sheath for hot water applications (Class X)

Model	Temper	Size (mm)
INSO PLUS	R250	15x0.7, 22x0.9, 28x0.9
	R290	35x1.2, 42x1.2, 54x1.2

4. Copper pipes with polyethylene sheath for cold water applications plus LSOH & FIRE RETARDANT (Class X)

Model	Temper	Size (mm)
INSO - LSOH & FIRE RETARDANT	R250	15x0.7, 22x0.9, 28x0.9
	R290	35x1.2, 42x1.2, 54x1.2, 66.7x1.2, 76.1x1.5, 108x1.5

5. Copper pipes with profiled polyethylene sheath for hot water applications plus LSOH & FIRE RETARDANT (Class X)

Model	Temper	Size (mm)
INSO PLUS - LSOH & FIRE RETARDANT	R250	15x0.7, 22x0.9, 28x0.9
	R290	35x1.2, 42x1.2, 54x1.2

Body Markings:

For Copper pipes (Class X) (R250):
tub-e ® PREMIUM BS EN 1057
(Size) x (Wall Thickness) HH

For Copper pipes (Class X) (R290):
tub-e ® PREMIUM BS EN 1057
(Size) x (Wall Thickness) R290

For Copper pipes with polyethylene sheath for cold water applications (Class X) (R250):
tub-e ® INSO EN 1057
HH (Size) x (Wall Thickness)

For Copper pipes with polyethylene sheath for cold water applications (Class X) (R290):

tub-e ® INSO EN 1057

R290 (Size) x (Wall Thickness)

For Copper pipes with profiled polyethylene sheath for hot water applications (Class X) (R250):

tub-e ® INSO PLUS EN 1057

HH (Size) x (Wall Thickness)

For Copper pipes with profiled polyethylene sheath for hot water applications (Class X) (R290):

tub-e ® INSO PLUS EN 1057

R290 (Size) x (Wall Thickness)

For Copper pipes with polyethylene sheath for cold water applications plus LSOH & FIRE RETARDANT (Class X) (R250):

tub-e ® INSO LSOH & FIRE RETARDANT

EN 1057 HH (Size) x (Wall Thickness)

For Copper pipes with polyethylene sheath for cold water applications plus LSOH & FIRE RETARDANT (Class X) (R290):

tub-e ® INSO LSOH & FIRE RETARDANT

EN 1057 R290 (Size) x (Wall Thickness)

For Copper pipes with profiled polyethylene sheath for hot water applications plus LSOH & FIRE RETARDANT (Class X) (R250):

tub-e ® INSO PLUS LSOH & FIRE RETARDANT

EN 1057 HH (Size) x (Wall Thickness)

For Copper pipes with profiled polyethylene sheath for hot water applications plus LSOH & FIRE RETARDANT (Class X) (R290):

tub-e ® INSO PLUS LSOH & FIRE RETARDANT

EN 1057 R290 (Size) x (Wall Thickness)

Expiry Date:

4 August 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only