



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(188/2025)

7 July 2025

**Approval of “LIDE” Flexible Joints
(General Acceptance No. ZC20250470)**

Your letters ref. BK2025-AC-LIDE-013, BK2025-AC-LIDE-013(V2) and BK2025-AC-LIDE-013(V3) dated 6 March 2025, 25 April 2025 and 6 June 2025 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2025-048 and BC-SUMMARY-2025-049 both issued on 17 February 2025 and ref. 250109-2436 issued on 17 February 2025 by Castco Testing Centre Ltd. and WRAS approval no. 241055059, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Lide Rubber & Plastic Co Ltd

Country of Origin: the Mainland of China

Brand: Lide

Details of Fittings: Twin sphere rubber flexible joint

Model: XTQ2RF-PN16, XTQ2RF-PN25



Size: 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm

Body Markings: For XTQ2RF-PN16:
 (DN) – PN16

For XTQ2RF-PN25:
 (DN) – PN25

Expiry Date: 6 July 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



XTQ2RF-PN16



XTQ2RF-PN25