



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞  
e-mail

wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile

2824 0578

檔號  
Reference

( 4 ) in WSD 3321/2025 T/J(478/2025)

7 July 2025

**Approval of “WATERFRONT” Gate Valves  
(General Acceptance No. ZC20250479)**

Your letters ref. L/25/W407 and L/25/W455 dated 26 May 2025 and 11 June 2025 respectively refer.

Having considered the test report ref. BC-SUMMARY-2025-175 issued on 9 June 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Waterfront Fluid Controls Limited

**Country of Origin:** the Mainland of China

**Brand:** Waterfront

**Details of Fittings:** Ductile iron resilient seated gate valve with epoxy powder coating under WRAS approval no. 2008501

**Model:** Series 224

**Size:** 65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm



**Body Markings:**

 (Production Year) (DN) SG RES  
PN25 BS5163-1 EN1074-2

**Expiry Date:**

31 August 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
             ME/MC            ] - with soft copy only



Series 224