



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(491/2025)

17 July 2025

**Approval of “KEMBLA” Copper Pipes
(General Acceptance No. ZC20250516)**

Your letters dated 29 April 2025 and 25 June 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-182 issued on 22 May 2025 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: MM Kembla

Country of Origin: Korea

Brand: Kembla

Details of Pipes:

1. Copper pipes (Type Y)

Temper	Size (mm)
R290	42x1.5, 54x2.0, 66.7x2.0, 76.1x2.0, 108x2.5

2. Copper pipes with plastic sheath (Type Y) (Kemline)
(cold water)

Temper	Size (mm)
R290	42x1.5, 54x2.0, 66.7x2.0, 76.1x2.0, 108x2.5



Body Markings:

For Copper pipes (Type Y):

KEMBLA EN1057 – Y (DN) X (Wall Thickness)
R290 BSI BENCHMARK (Production code)

For Copper pipes with plastic sheath (Type Y) (Kemline)
(cold water):

KEMBLA KEMLINE PLUS ® COPPER TUBE IS
EN1057 – Y (DN) X (Wall Thickness) R290 BSI
BENCHMARK (Production code)

Expiry Date:

27 July 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only