



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(532/2025)

31 July 2025

**Approval of “K.W. (KOON WAH)” Ductile Iron Pipes
(General Acceptance No. ZC20250556)**

Your letters ref. KW20250606SFPIP25CWSD and
KW20250709SFPIP25CWSD dated 6 June 2025 and 9 July 2025 respectively refer.

Having considered the test reports ref. BC-SUMMARY-2024-184 issued on 24 June 2025 and ref. 250203-2162 issued on 23 June 2025 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: the Mainland of China

Brand: K.W. (Koon Wah)

Details of Pipes: Ductile iron pipes with screw-on flanged (Class C) with internal cement mortar lining under WRAS approval no. 2010529

Size: 80mm, 100mm, 150mm, 200mm

Body Markings:  DI BS EN 545 K12
(Class) (DN) (Production code)



東江水供港



香港環境卓越獎
Hong Kong Centre for Environmental Excellence



15 years+
同心展關懷
Awarded by the Hong Kong Council of Social Service
香港社會服務會頒發

Expiry Date: 30 July 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,




(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Ductile iron pipes with screw-on flanged (Class C)