



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(533/2025)

31 July 2025

**Approval of “K.W. (KOON WAH)” Ductile Iron Fittings
(General Acceptance No. ZC20250557)**

Your letters ref. KW20250606FFPN25WSD and KW20250709FFPN25WSD dated 6 June 2025 and 9 July 2025 respectively refer.

Having considered the test reports ref. DP-SUMMARY-2025-081, DP-SUMMARY-2025-082 and DP-SUMMARY-2025-083 all issued on 3 March 2025 and ref. 250203-2162 issued on 23 June 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shandong Jianhua Valve Manufacturing Co Ltd

Country of Origin: the Mainland of China

Brand: K.W. (Koon Wah)

Details of Fittings: Ductile iron fittings with internal cement mortar lining under WRAS approval no. 2010529

Description	Size (mm)
Double Flanged 90° Bend	250



Description	Size (mm)
All Flanged Tee	250x250x250
Double Flanged Taper	250x80, 250x100

Body Markings:

For Double Flanged Bend:



DI BS EN 545 PN25 K12 size x angle

For Others:



DI BS EN 545 PN25 K12 size x size

Expiry Date:

30 July 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,

(Terry KUNG)


for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Flanged 90° Bend



All Flanged Tee



Double Flanged Taper