



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(744/2025)

14 August 2025

**Approval of “MR” Ductile Iron Fitting
(General Acceptance No. ZC20250604)**

Your letter ref. MR-DFBEND.18072025 dated 18 July 2025 refers.

Having considered the test reports ref. BC-SUMMARY-2025-294 issued on 7 July 2025 and ref. 241204-2116 issued on 20 March 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: XinFeng Pipe Fittings Co Ltd

Country of Origin: the Mainland of China

Brand: MR

Details of Fitting: Ductile iron fitting with epoxy powder coating under WRAS approval no. 240455041

Description	Model	Size (mm)
Double Flanged Duckfoot 90° Bend	DF90DFB	150

Body Markings: MR BS EN 545 DI K12 size x angle PN16



Expiry Date: 13 August 2030

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



DF90DFB