



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(837/2025)

27 August 2025

**Approval of “CLA-VAL” Pressure Reducing Valves
(General Acceptance No. ZC20250650)**

Your E-Application [file-id: ETJ-GA-20250815-229] dated 15 August 2025 refers.

Having considered the test report ref. BC-SUMMARY-2025-130 issued on 8 August 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cla-Val Pacific Ltd

Country of Origin: Canada

Brand: Cla-Val

Details of Fittings: Ductile iron pressure reducing valve with epoxy powder coating under WRAS approval no. 2202530

Model: 690-01

Size: 65mm, 80mm, 100mm, 150mm, 200mm, 250mm, 300mm



Body Markings: CLA-VAL (Inch) / (DN) 150 / (PN)

Expiry Date: 26 August 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



690-01