



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(780/2025)

3 September 2025

**Approval of “PHW” PE Pipes
(General Acceptance No. ZC20250673)**

Your E-Application [file-id: ETJ-GA-20250728-203] dated 29 July 2025 and subsequent submission received by this department on 8 August 2025 refer.

Having considered the test reports ref. BC-SUMMARY-2025-037 and 241211-2132 issued on 23 July 2025 and 11 March 2025 respectively by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: ShanDong TengYuan Building Materials Technology Co Ltd

Country of Origin: the Mainland of China

Brand: PHW

Details of Pipes: PE pipes in blue colour (PE100, SDR11)

Size: 32mm, 50mm, 63mm, 90mm, 125mm, 180mm, 250mm, 315mm

Body Markings: PHW (Size) x (Wall Thickness) SDR11 1.6MPA
PE100RC BS EN 12201 (Production Code)



東江水供港



香港環境保護署
Hong Kong Environment Protection Department



15 years+ 同心展關懷
caringorganisation
Approved by The Hong Kong Council of Social Service
香港社會服務會

Expiry Date: 2 September 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only