



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail
wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile
2824 0578

檔號
Reference
(6) in WSD 3321/2025 T/J(471/2025)

4 September 2025

**Approval of "TUB-E" Copper Fittings
(General Acceptance No. ZC20250675)**

Your letter ref. BK2025-AC-TUBEF-020 dated 26 May 2025 and subsequent submissions received by this department up to 12 August 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-184 issued on 11 July 2025 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Zhuji City Howhi Air Conditioners Made Co Ltd

Country of Origin: the Mainland of China

Brand: tub-e

Details of Fittings: Copper fittings with end feed connection ends

Description	Model	Size (mm)
90° Elbow	204	159
45° Elbow	224	159
Equal Tee	205	159



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ 同心展關懷
caringorganisation
Advanced by The Hong Kong Council of Social Service
香港社會服務會

Description	Model	Size (mm)
Reducing Tee	206	159x159x54, 159x159x66.7, 159x159x76.1, 159x159x108
Coupler	201	159
Reducer	202	159x76.1, 159x108
Reducing Bush	203	159x76.1, 159x108

Body Markings: tub-e EN1254 (Size)

Expiry Date: 15 October 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)
for Director of Water Supplies

Encl.


c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



90° Elbow



45° Elbow



Equal Tee



Reducing Tee



Coupler



Reducer



Reducing Bush