



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(906/2025)

22 October 2025

**Approval of "BLANCO" Sink Mixer
(General Acceptance No. ZC20250802)**

Your E-Application [file-id: ETJ-GA-20250828-259] dated 29 August 2025 and subsequent submission received by this department on 25 September 2025 refer.

Having considered the test reports ref. 235369PC233279D and 250478EN250994 issued on 14 August 2025 and 11 July 2025 by Fugro Technical Services Limited and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Blanco GmbH + Co KG

Country of Origin: Chinese Mainland

Brand: Blanco

Details of Fitting: 3/8" Single lever sink mixer with
1) 1 no. of flexible hose under test report ref. 250478EN250994 &
2) 1 no. of flexible hose approved by UK's WRAS under ref. 250702033

Model: LINUS-SX
(where "X" denotes the code of colour)



東江水供港



香港環境廳
Hong Kong Authority for Environmental Excellence



15 years+
同心展關懷
caringorganisation
Supported by The Hong Kong Council of Social Service
香港社會服務會

Body Markings:

BLANCO

Expiry Date:

21 October 2030

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



LINUS-SX