



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(4) in WSD 3321/2025 T/J(899/2025)

24 October 2025

**Approval of "TOWNTUBE" Galvanized Steel Pipe
(General Acceptance No. ZC20250814FS)**

Your letters dated 1 September 2025 and 29 September 2025 refer.

Having considered the test report ref. 250380PC250492A issued on 23 September 2025 by Fugro Technical Services Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Nanhai Shungang Pipe Industry Co Ltd

Country of Origin: Chinese Mainland

Brand: Towntube

Details of Pipe: Galvanized steel pipe

Size: 200mm x 5.0mm

Body Markings: TOWNTUBE EN 10217-1 W DN size x length

Expiry Date: 23 October 2030



Proviso: The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only