



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(1004/2025)

31 October 2025

**Approval of "TYT" Bib Tap
(General Acceptance No. ZC20250833)**

Your letter ref. WSD-30-09-2025B dated 30 September 2025 refers.

Having considered the test report ref. 251447PC250460(2)A issued on 29 September 2025 by Fugro Technical Services Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: M/s Goodyear Valves Works Corp

Country of Origin: Taiwan, China

Brand: TYT

Details of Fitting: 1/2" Bib tap

Model: TYT-802L*
(where the digit " * " denotes the code of handle)

Body Markings: T.Y.T. 1/2

Expiry Date: 30 October 2030



東江水供港



香港環保卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ caring organisation

ANDREWS & YIP THE HONG KONG GOVERNMENT SOCIAL SERVICE

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TYT-802L*