



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(875/2025)

3 November 2025

**Approval of “CLA-VAL” Float Valves
(General Acceptance No. ZC20250838)**

Your E-Application [file-id: ETJ-GA-20250828-260] dated 28 August 2025 and subsequent submissions received by this department up to 28 October 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-365 issued on 7 August 2025 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cla-Val Pacific Ltd

Country of Origin: Canada

Brand: Cla-Val

Details of Fittings: Ductile iron float valve with epoxy powder coating under WRAS approval no. 2202530

Model: 129-01S

Size: 40mm, 50mm

Body Markings: CLA-VAL (Inch) / (DN) 300 / (PN)



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years caring organisation

Supported by The Hong Kong Council of Social Service
香港社會服務會

Expiry Date: 2 November 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



129-01S