



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (5) in WSD 3321/2025 T/J(857/2025)

6 November 2025

**Approval of “WEFLO” Pressure Reducing Valves
(General Acceptance No. ZC20250857)**

Your letter dated 18 August 2025 and subsequent submissions received by this department up to 6 October 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-342 issued on 2 October 2025 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Weflo Valve Co Ltd

Country of Origin: Chinese Mainland

Brand: Weflo

Details of Fittings: Ductile iron pressure reducing valve with epoxy coating under WRAS approval no. 2104506

Model: 1320-300

Size: 100mm, 150mm

Body Markings: Model 1320-300

Expiry Date: 5 November 2030



This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.


Yours faithfully,



(Terry KUNG)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



1320-300