



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電 話
Telephone

圖文傳真
Facsimile 2824 0578

檔 號
Reference (4) in WSD 3321/2025 T/J(943/2025)

12 November 2025

**Approval of “MC MAN CHIT” Galvanized Steel Pipes
(General Acceptance No. ZC20250870FS)**

Your letter ref. K281120-02/WSD-MCAPL/2025 dated 2 September 2025 and subsequent submission received by this department on 15 October 2025 refer.

Having considered the test report ref. RMCI006 issued on 1 September 2025 by Ideal Test Consultants Ltd., this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tianjin Youfa Steel Pipe Group Co Ltd

Country of Origin: Chinese Mainland

Brand: MC Man Chit

Details of Pipes: Galvanized steel pipes

Size: 200mm x 5.6mm, 200mm x 6.3mm

Body Markings: MC Man Chit ® BSEN10217
W size x thickness x length (M)

Expiry Date: 11 November 2030



Proviso: The pipes can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipes in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only