



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(877/2025)

14 November 2025

**Approval of “BOLTON” Ductile Iron Pipes
(General Acceptance No. ZC20250879)**

Your letter ref. AL/5517/WSD/GA+ dated 26 August 2025 and subsequent submissions received by this department up to 20 October 2025 refer.

Having considered the test reports ref. BC-SUMMARY-2025-333 issued on 8 August 2025 and ref. 250519-2632 issued on 19 September 2025 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Xinxing Ductile Iron Pipes Co Ltd

Country of Origin: Chinese Mainland

Brand: Bolton

Details of Pipes: K12 Ductile iron socket and spigot pipes with internal cement mortar lining under WRAS approval no. 240355013

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm

Body Markings: BOLTON Ductile Iron BS EN 545 K12
DIP T TYPE size x length class



Expiry Date:

13 November 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



K12 Ductile iron socket and spigot pipes