



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(6) in WSD 3321/2024 T/J(810/2025)

20 November 2025

**Approval of “NUPI” PE Pipes
(General Acceptance No. ZC20250894)**

Your letters dated 5 August 2025, 26 September 2025 and 22 October 2025 refer.

Having considered the test reports ref. PMA51419A issued on 11 September 2025 by ETS-Testconsult Limited and ref. 250822-2125 issued on 17 September 2025 by Castco Testing Centre Limited and WRAS approval no. 2303548, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: NUPI Industrie Italiane SpA

Country of Origin: Italy

Brand: NUPI

Details of Pipes: PE pipes in blue colour (PE100, SDR11)

Size: 32mm, 50mm, 250mm



Body Markings:

For 32mm and 50mm:

NUPI NADIR PLUS BS EN12201 ISO4427
 BS6920 DN/OD x Wall thickness PN16 SDR11
 PE100 RC WATER B94HP Batch No.

For 250mm:

=P316= NUPI NADIR PLUS kiwa @ IT-TD-Ki0410
 K01-02 K58-01 UNI BS EN12.201 ISO4427
 DN/OD x Wall thickness PN16 SDR11 =2008A=
 Batch No. PE100 RC W B94H P

Expiry Date:

19 November 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only