



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞  
e-mail      wsdinfo@wsd.gov.hk

電話  
Telephone

圖文傳真  
Facsimile      2824 0578

檔號  
Reference      ( 4 ) in WSD 3321/2025 T/J(1047/2025)

19 December 2025

**Approval of “WELSON” Float Valves  
(General Acceptance No. ZC20250970)**

Your letter ref. WEL-2001LF-26092025AP dated 26 September 2025 and subsequent submission received by this department on 21 November 2025 refer.

Having considered the test report ref. 252474PC250753A issued on 12 November 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** FS Welson Metal Manufacturing Company Limited

**Country of Origin:** Chinese Mainland

**Brand:** Welson

**Details of Fittings:** Copper alloy float valve

**Model and Size:**

|           |        |
|-----------|--------|
| 2001LF-20 | - 20mm |
| 2001LF-25 | - 25mm |
| 2001LF-32 | - 32mm |
| 2001LF-40 | - 40mm |
| 2001LF-50 | - 50mm |



2001LF-65 - 65mm  
2001LF-80 - 80mm  
2001LF-100 - 100mm

**Body Markings:**  WELSON size in inch LF

**Expiry Date:** 18 December 2030

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)  
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



2001LF-20 / 2001LF-25 / 2001LF-32 / 2001LF-40 / 2001LF-50 /  
2001LF-65 / 2001LF-80 / 2001LF-100