



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(1123/2025)

29 December 2025

**Approval of “GAMMAP” PE Pipes
(General Acceptance No. ZC20250987)**

Your letter ref. KW06112025-PEBKPIPWSD dated 6 November 2025 and subsequent submissions received by this department up to 27 November 2025 refer.

Having considered the test reports ref. DP-SUMMARY-2025-478 and 250801-2766 issued on 6 October 2025 and 28 October 2025 respectively by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Guangzhou Fenye Pipe Industrial Co Ltd

Country of Origin: Chinese Mainland

Brand: Gammap

Details of Pipes: PE pipes in black colour (PE100, SDR11)

Size: 25mm, 32mm, 40mm, 50mm, 63mm, 90mm, 125mm, 180mm, 250mm, 315mm

Body Markings:  water PE100 (DN) x (wall thickness)
SDR11 PN16 EN12201



Expiry Date: 28 December 2030

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only