



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/2025 T/J(909/2025)

30 December 2025

**Approval of “VALVULAS CT” Float Valve
(General Acceptance No. ZC20250991)**

Your E-Application [file-id: ETJ-GA-20250902-267] dated 4 September 2025 and subsequent submissions received by this department up to 1 December 2025 refer.

Having considered the test report ref. BC-SUMMARY-2025-356 issued on 30 September 2025 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Genwec Washroom SL

Country of Origin: Spain

Brand: Valvulas CT

Details of Fitting: 50mm Duplex stainless steel float valve

Model: 200A-RPHS

Body Markings: CT AISI

Expiry Date: 29 December 2030



This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



200A-RPHS