



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(1051/2025)

21 January 2026

**Approval of “WELSON” Float Valves
(General Acceptance No. ZC20260054)**

Your letter ref. WEL-106-26092025AP dated 26 September 2025 and subsequent submissions received by this department up to 24 December 2025 refer.

Having considered the test report ref. 251409PC250630A issued on 18 December 2025 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: FS Welson Metal Manufacturing Company Limited

Country of Origin: Chinese Mainland

Brand: Welson

Details of Fittings: Stainless steel float valve

Model and Size:
106-20 - 20mm
106-25 - 25mm
106-32 - 32mm
106-40 - 40mm
106-50 - 50mm



106-65 - 65mm
106-80 - 80mm
106-100 - 100mm
106-150 - 150mm

Body Markings:

For 20mm:
W20 WELSON

For Others:
W (size) WELSON model

Expiry Date:

20 January 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



106-20 / 106-25 / 106-32 / 106-40 / 106-50 /
106-65 / 106-80 / 106-100 / 106-150