



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/2025 T/J(1154/2025)

2 February 2026

**Approval of “SINOTEC” Ductile Iron Pipes
(General Acceptance No. ZC20260086)**

Your letters ref. 1127/2025 and 1225/2025 dated 12 November 2025 and 31 December 2025 respectively refer.

Having considered the test reports ref. PMA52313 issued on 6 November 2025 & ref. AGA50538 issued on 23 December 2025 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jilin Senfeng Pipe Co Ltd

Country of Origin: Chinese Mainland

Brand: Sinotec

Details of Pipes: K9 Ductile iron socket and spigot pipes with internal cement mortar lining under WRAS approval no. 2207526

Size: 80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 400mm, 450mm, 600mm

Body Markings: SINOTEC Ductile Iron Pipe BS EN 545 class K9 size x length



東江水供港
Tung Chung Water Supply Project



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ caring organisation
Awarded by The Hong Kong Council of Social Service
獲頒發香港社會服務會

Expiry Date: 1 February 2031

This Authority hereby permits the use of the above pipes in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



K9 Ductile iron socket and spigot pipes