



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile

2824 0578

檔號
Reference

(2) in WSD 3321/2025 T/J(555/2025)

3 February 2026

**Approval of “PHILMAC” Pressure Reducing Valve
(General Acceptance No. ZC20260089FS)**

Your E-Application [file-id: ETJ-GA-20250610-140] dated 10 June 2025 and subsequent submissions received by this department up to 7 January 2026 refer.

Having considered the test report ref. BC-SUMMARY-2025-098 issued on 7 August 2025 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Philmac Pty Ltd

Country of Origin: Australia

Brand: Philmac

Details of Fitting: Copper alloy pressure reducing valve

Model: Cat No. 2649

Size: 80mm

Body Markings: PHILMAC ➡



東江水供港



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



15 years+ caring organisation
Awarded by The Hong Kong Council of Social Service

Expiry Date: 2 February 2031

Proviso: The fitting can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above fitting in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water fire service systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Cat No. 2649