



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(1099/2025)

20 February 2026

**Approval of “BOLTON” Ductile Iron Fittings
(General Acceptance No. ZC20260115)**

Your letter ref. AL/5531/WSD/GA+ dated 27 October 2025 and subsequent submissions received by this department up to 22 January 2026 refer.

Having considered the test reports ref. PMA52200B issued on 13 January 2026 by ETS-Testconsult Ltd. and ref. 250416-2334 issued on 25 July 2025 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Foshan Chanshan Foundry Co Ltd

Country of Origin: Chinese Mainland

Brand: Bolton

Details of Fittings: Ductile iron fittings with internal cement mortar lining

Description	Model	Size (mm)
Double Flanged Taper PN16	FCTPR	40x32, 50x32, 50x40, 65x32, 65x40, 65x50, 80x32, 80x40, 80x50, 80x65, 100x32, 100x40, 100x50, 100x65, 100x80, 125x100, 150x50, 150x65, 150x80, 150x100, 150x125, 200x100, 200x150, 250x100, 250x200, 300x250



Description	Model	Size (mm)
Double Socket Taper	PCTPR	100x80, 150x80, 150x100, 200x100, 200x150, 250x150, 250x200, 300x150, 300x200, 300x250
Double Flanged Taper PN25	FCTPR	100x50, 100x80, 150x100

Body Markings:

For Double Flanged Tapers:

 BS EN 545 DI K12 (PN)
 size x size FZ (Production ID)

For Others:

 BS EN 545 DI K12
 size x size FZ (Production ID)

Expiry Date:

19 February 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Double Flanged
Taper PN16



Double Socket Taper



Double Flanged
Taper PN25