



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong.

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone

圖文傳真
Facsimile 2824 0578

檔號
Reference (6) in WSD 3321/2025 T/J(1112/2025)

3 March 2026

**Approval of “VALVE LEADER” Gate Valves
(General Acceptance No. ZC20260131)**

Your letters dated 23 October 2025, 11 December 2025 and 3 February 2026 refer.

Having considered the test reports ref. PMA51674A and AGA50379A issued on 3 December 2025 and 1 December 2025 by ETS-Testconsult Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Yantai Valve Factory
Country of Origin:	Chinese Mainland
Brand:	Valve Leader
Details of Fittings:	Ductile iron metal seated gate valve with epoxy powder coating under WRAS approval no. 250355085
Model:	VL16-M
Size:	80mm, 100mm, 150mm, 200mm, 250mm, 300mm, 350mm, 400mm, 450mm, 500mm, 600mm



Body Markings: BE EN 1074-2 BS 5163-1 Year
Nominal size PN16 DI CF

Expiry Date: 2 March 2031


This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(CHAN Kwok Leung, Douglas)
for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



VL16-M